

DG79A06TH01



A	Model	B	Indoor unit		MSZ-AY25VGKP MSZ-AY25VGK		MSZ-AY35VGKP MSZ-AY35VGK		MSZ-AY42VGKP MSZ-AY42VGK		MSZ-AY50VGKP MSZ-AY50VGK			
			C	Outdoor unit	MUZ-AY25VG	MUZ-AY25VGH	MUZ-AY35VG	MUZ-AY35VGH	MUZ-AY42VG	MUZ-AY42VGH	MUZ-AY50VG	MUZ-AY50VGH		
D	Sound power levels on cooling mode	E	Inside	dB	57	57	57	57	57	57	58	58		
			F	Outside	dB	59	59	61	61	61	61	64	64	
G Refrigerant														
R32 GWP 675 *1														
H	Cooling	SEER			8,7	8,7	8,7	8,7	7,9	7,9	7,5	7,5		
		J Energy efficiency class			A+++	A+++	A+++	A+++	A++	A++	A++	A++		
		K Annual electricity consumption *2 kWh/a			100	100	141	141	186	186	232	232		
		L Design load			2,5	2,5	3,5	3,5	4,2	4,2	5,0	5,0		
M	Heating (Average / Warmer / Colder season)	SCOP			4,8 / 5,7 / -	4,7 / 5,7 / -	4,7 / 5,9 / -	4,6 / 5,9 / -	4,7 / 5,9 / -	4,6 / 5,9 / -	4,7 / 6,1 / -	4,6 / 6,1 / -		
		J Energy efficiency class			A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -	A++ / A+++ / -		
		K Annual electricity consumption *2 kWh/a			697 / 319 / -	709 / 319 / -	863 / 376 / -	880 / 376 / -	1131 / 495 / -	1146 / 495 / -	1248 / 523 / -	1265 / 523 / -		
		L Design load			2,4 / 1,3 / -	2,4 / 1,3 / -	2,9 / 1,6 / -	2,9 / 1,6 / -	3,8 / 2,1 / -	3,8 / 2,1 / -	4,2 / 2,3 / -	4,2 / 2,3 / -		
		N	De- clared capacity	P	at reference de- sign temperature	kw	2,4(-10°C)/1,3(2°C) / -	2,4(-10°C)/1,3(2°C) / -	2,9(-10°C)/1,6(2°C) / -	2,9(-10°C)/1,6(2°C) / -	3,8(-10°C)/2,1(2°C) / -	3,8(-10°C)/2,1(2°C) / -	4,2(-10°C)/2,3(2°C) / -	4,2(-10°C)/2,3(2°C) / -
				R	at bivalent tem- perature	kw	2,4(-10°C)/1,3(2°C) / -	2,4(-10°C)/1,3(2°C) / -	2,9(-10°C)/1,6(2°C) / -	2,9(-10°C)/1,6(2°C) / -	3,8(-10°C)/2,1(2°C) / -	3,8(-10°C)/2,1(2°C) / -	4,2(-10°C)/2,3(2°C) / -	4,2(-10°C)/2,3(2°C) / -
				S	at operation limit temperature	kw	1,9(-20°C)/1,9(-20°C) / -	1,9(-20°C)/1,9(-20°C) / -	2,0(-20°C)/2,0(-20°C) / -	2,0(-20°C)/2,0(-20°C) / -	2,7(-20°C)/2,7(-20°C) / -	2,7(-20°C)/2,7(-20°C) / -	3,0(-20°C)/3,0(-20°C) / -	3,0(-20°C)/3,0(-20°C) / -
		T	Back up heating capacity			kw	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	0,0(-10°C)/0,0(2°C) / -	

	Deutsch	Italiano	Svenska	Polski	Eesti	Malti	Русский
	Français	Ελληνικά	Česky	Slovensko	Gaeilge	Suomi	Norsk
	Nederlands	Português	Slovensky	Български	Latviski	Türkçe	Українська
	Español	Dansk	Magyar	Română	Lietuvių k.	Hrvatski	
A	Modell	Modello	Modell	Model	Mudel	Mudell	Модель
	Modèle	Μοντέλο	Model	Model	Déanamh	Malli	Modell
	Model	Modelo	Model	Модел	Modelis	Model	Модель
	Modelo	Model	Modell	Model	Modelis	Model	
B	Innengerät	Unità interna	Inomhusenhet	Jednostka wewnętrzna	Siseseade	Unità għal gewwa	Внутренний прибор
	Appareil intérieur	Εσωτερική μονάδα	Vnitřní jednotka	Notranja enota	Aonad laistigh	Sisäyksikkö	Innendørsenhett
	Binnenunit	Unidade interior	Vnútrná jednotka	Вътрешно тяло	Iekšējai ierīce	Iç ünite	Внутрішній блок
	Unidad interior	Indendørsenhed	Beltéri egység	Unitate de interior	Patalpoje montuojamas įrenginys	Unutarnja jedinica	
C	Außengerät	Unità esterna	Utomhusenhet	Jednostka zewnętrzna	Välisseade	Unità għal barra	Наружный прибор
	Modèle extérieur	Εξωτερική μονάδα	Vnější jednotka	Zunanja enota	Aonad lasmuigh	Ulkoyksikkö	Utdendørsenhett
	Buitenunit	Unidade exterior	Vonkajšia jednotka	Външно тяло	Ārtelpas ierīce	Diş ünite	Зовнішній блок
	Unidad exterior	Udendørsenhed	Kültéri egység	Unitate de exterior	Lauke montuojamas įrenginys	Vanjska jedinica	
D	Schalleistungspegel im Kühlmodus	Livelli di potenza sonora in modalità di raffreddamento	Bullernivå i nedkylningsläget	Poziom mocy dźwięku w trybie chłodzenia	Müratasemed jahutusrežiimis	Livelli tal-qawwa tal-hsejjes fil-modalità tat-tkessih	Значения уровня звуковой мощности в режиме охлаждения
	Niveaux de puissance corrects en mode de refroidissement	Επίπεδα ισχύος ήχου στην κατάσταση ψύξης	Úrovně hluchosti v režimu chlazení	Ravni zvočne moči v načinu hlajenje	Leibhéal chumhachta fuaiame ar mhodh fuairithe	Äänenvoimakkuaustasot viilen-nystilassa	Lydtrykknivåer i avkjølingsmodus
	Geluidsniveaus in koelstand	Níveis de potência sonora em modo de arrefecimento	Hladiny akustického výkonu v režime chladenia	Нива на звуковата мощност в режим на охлаждане	Akustiskās jaudas līmenis dzēsēšanas režīmā	Soğutma modunda ses gücü düzeyleri	Рівні звукової потужності у режимі охолодження
	Niveles de potencia del sonido en el modo de refrigeración	Lydstyrkeniveauer i kølefunktion	Hangnyomásszintek hűtés üzemi-módban	Nivel sonor în modul de răcire	Garso galios lygis vėsinimo režimu	Razine zvučnog tlaka pri hlađenju	
E	Innen	Interno	Insida	Wewnątrz	Sees	Ġewwa	Внутри
	À l'intérieur	Εσωτερικό	Uvnitř	Znotraj	Laistigh	Sisäpuoli	Innwendig
	Binnenkant	Interior	Vo vnútri	Вътре	Iekšējās	Iç taraf	Усередині
	Interior	Indvendig	Bent	Interior	Vidinis	Unutra	
F	Außen	Esterno	Utsida	Na zewnątrz	Väljas	Barra	Снаружи
	À l'extérieur	Εξωτερικό	Venku	Zunaj	Lasmuigh	Ulkopuoli	Utvendig
	Buitenkant	Exterior	Vonku	На открито	Ārtelpā	Diş taraf	Назовні
	Exterior	Udvendig	A szabadban	Exterior	Išorinis	Vani	
G	Kühlmittel	Refrigerante	Köldmedel	Czynnik chłodniczy	Kūlmutusagens	Refrigerant	Хладагент
	Réfrigérant	Ψυκτικό	Chladivo	Hladilno sredstvo	Cuisnean	Kylmäaine	Kjølemedium
	Koelmiddel	Refrigerante	Chladivo	Хладилен агент	Aukstumaģents	Soğutucu	Холодоагент
	Refrigerante	Kølemiddel	Hűtőközeg	Refrigerent	Šaldams	Rashladno sredstvo	

		Deutsch	Italiano	Svenska	Polski	Eesti	Malti	Русский
		Français Nederlands Español	Ελληνικά Português Dansk	Česky Slovensky Magyar	Slovensko Български Română	Gaeilge Latviski Lietuvių k.	Suomi Türkçe Hrvatski	Norsk Українська
Ⓕ		Kühlen Refroidissement Koelen Refrigeración	Raffreddamento Ψύξη Arrefecimento Køling	Kyla Chlazení Chladenie Hütés	Chłodzenie Hlajenje Охлаждане Răcire	Jahutus Fuarú Dzēsēšana Vésinimas	Tkessih Viilennys Soğutma Hlađenje	Охлаждение Avkjøling Охолодження
		Energieeffizienzklasse Classe d'efficacité énergétique Energie-efficiëntieklasse Clase de eficiencia energética	Classe di efficienza energetica Κλάση ενεργειακής απόδοσης Classe de eficiencia energética	Energiklass Třída energetické účinnosti Trieda energetickej účinnosti	Klasa energetyczna Razred energetске učinkovitosti Клас на енергийна ефективност	Energiatõhususe klass Aicme éifeachtúlachta fuinnimh Energoefektivitātes klase Enerģijas vartojimo efektyvumo klasė	Klassi tal-effiċjenza fl-użu tal- enerġija Energiatehokkuusluokka Enerji verimlilik sınıfı	Класс эффективности использования энергии Energieeffektivitetsklasse Клас ефективності енергоспоживання
		Jahresstromverbrauch *2 Consommation d'électricité an- nuelle *2 Jaarlijks elektriciteitsverbruik *2 Consumo anual de electricidad *2	Consumo annuale di energia elettrica *2 Ετήσια κατανάλωση ρεύματος *2 Consumo anual de electricidade *2 Årligt elforbrug *2	Årlig strömförbrukning *2 Roční spotřeba elektrické energie *2 Ročná spotreba elektriny *2 Éves áramfogyasztás *2	Zużycie prądu w skali roku *2 Letna poraba elektrike *2 Годишна консумация на електроенергия *2 Consum anual de electricitate *2	Aastane voolutarbimus *2 Ídiü leicteachais bhliantúil *2 Gada elektroenerģijas patēriņš *2 Metinis elektros energijos suvar- tojimas *2	Konsum annwali tal-elettriku *2 Vuotuinen sähkönkulutus *2 Yıllık elektrik tüketimi *2 Godišnja potrošnja električne energije *2	Годовое потребление электроэнергии *2 Årlig strømforbruk *2 Річне споживання електроенергії *2
Ⓛ		Lastauslegung Charge de calcul Ontwerpbelasting Carga de diseño	Carico nominale Σχεδιασμός φόρτωσης Carga nominal Brugslast	Dimensionerande belastning Jmenovitě zatížení Projektované zaťaženie Mértelési terhelés	Maksymalne obciążenie Nazivna obremenitev Łód deartha Projektен товар Sarcină nominală	Projekteeritud koormus Lód deartha Aprékina slodze Projektiné apkrova	Tagħbiż tad-disinn Laskettu kuormitus Tasarim yūkù Teżina uređaja	Расчетная нагрузка Utformingsbelastning Розрахункове навантаження
		Heizung (Durchschnitt / Wärmer / Kälter / Jahreszeit) Chauffage (Moyenne / Plus chaud / Plus froid / saison) Verwarming (gemiddeld seizoen / warmer seizoen / kouder seizoen) Calefacción (temporada promedio / tem- porada más cálida / temporada más fría)	Riscaldamento (Stagione media / calda / fredda) Θέρμανση (Εποχή με μέσες / υψηλότερες / χαμηλότερες θερμοκρασίες) Aquecimento (Média estação / Es- tação mais quente / Estação mais fria) Opvarmning (genomsnittlig/var- mere/koldere/sæson)	Värme (Genomsnittlig/varmare/ kallare årstid) Topení (průměrná/teplá/studená sezóna) Kúrenie (priemerné/teplejšie/ chladnejšie obdobie) Fűtés (átlagos/melegebb/hidegebb/ évszak)	Ogrzewanie (umiarkowane / cie- plejsze / zimniejsze / sezonowe) Ogrevanje (povprečni/toplejši/ hladnejši letni čas) Отопление (Средно / Топъл / Студен сезон) Incălzire (Anotimp normal/mai cald/mai rece)	Kütmine (keskmise/soojem/kül- mem periood) Téamh (Meánteocht / Níos Teo/ Níos Fuairse / séasúr) Sildimis (vidutinis / šiltesnis / šaltesnis / sezoninis) Šildymas (vidutinis / šiltesnis / šaltesnis / sezoninis)	Tishin (Medju / Aktar shun / Aktar kiesah / stagun) Lämmitys (Välikausi / lämmin kausi / kylmä kausi) İstima (Ortalama / Daha sıcak / Daha soğuk / mevsim) Grijanje (prosječno / toplije / hlad- nije / sezona)	Нагрев (средний/теплый/ холодный сезон) Varme (Middels / Varmere / Kal- dere / årstid) Опалення (у середній/теплій/ холодний сезон)
Ⓝ		Nennkapazität Capacité déclarée Aangegeven capaciteit Capacidad declarada	Capacità dichiarata Δηλωμένη χωρητικότητα Capacidade declarada Erklæret kapacitet	Deklarerad kapacitet Uđaváná kapacita Deklarovaný výkon Névleges teljesítmény	Deklarowana pojemność Prijavljena zmogljivost Объявeна мощность Capacitate declarată	Deklareeritud võimsus Toileadh fógartha Deklarētais jauda Deklaruotasis pajėgumas	Kapacitá dđikjarata Ilmoitettu teho Beyan edilen kapasite Deklarirani kapacitet	Гарантированная мощность Erklært kapasitet Гарантована потужність
		bei angegebener Referenztem- peratur à la température de calcul de référence bij referentieontwerptemperatuur a temperatura de diseño de referencia bei bivalenter Temperatur à température bivalente bij bivalente temperatuur a temperatura bivalente	alla temperatura di progetto di riferimento σε θερμοκρασία σχεδιασμού αναφοράς à temperatura nominal de refer- ència ved brugsafhængig referencetem- peratur alla temperatura bivalente σε θερμοκρασία διαθενοús λειτουργίας à temperatura bivalente ved bivalent temperatur	vid dimensionerande referenstem- peratur při referenční výpočtové teplotě pri referenčnej výpočtovej teplote tervezési referencia- hőmérsékleten vid bivalent temperatur při bivalentní teplotě pri bivalentnej teplote bivalens hőmérsékleten	w znamionowej temperaturze odniesienia ob referenčni nazivni temperaturi при изчислителна проектна температура la temperatura de referință nominală w temperaturze bivalentnej při bivalentni temperaturi при бивалентна температура la temperatura de bivalentă	projekteerimise võrdlustemperatu- uri juures ag toecht deartha tagartha aprékina references temperatūrā esant norminei projektinei temperatūrai bivalentse temperatuuri juures ag toecht dhéifiusach bivalentā temperatūrā esant perėjimo į dvejojo šildymo režimą temperatūrai	f'temperatura tad-disinn ta' referenza perusmitoitusslämpötilassa referans tasarim sıcaklığında pri referentnoj temperaturi f'temperatura bivalenti kaksiarvoisessa lämpötilassa iki deđerli sıcaklıkta pri bivalentnoj temperaturi	при эталонной расчетной температуре ved referansetemperatur for utforming При еталонній розрахунковій температурі при бивалентной температуре ved bivalent temperatur При бивалентній температурі
Ⓢ		bei Temperatur an der Betrieb- sgrenze à température de fonctionnement limite bij grens werkingstemperatuur a temperatura límite de funcio- n-amiento	alla temperatura limite di funzi- onamento σε θερμοκρασία ορίου λειτουργίας à temperatura de limite de fun- cionamiento ved driftsgrænsetemperatur	vid driftstemperaturens gränsvärde při teplotě na hranici provozního limitu pri hraničnej prevádzkovej teplote maximális üzemi hőmérsékleten	w granicznej temperaturze roboczej pri mejni delovni temperaturi при гранична работна температура la temperatura limită de funcionare	tõötamise piirtemperatuuri juures ag toecht teorann oiðriúcháin ekspluatācijas robežtemperatūrā esant ribinei veikimo temperatūrai	f'temperatura tal-limitu tat-thaddim toimintarajälämpötilassa çalışma limiti sıcaklığında pri graničnoj radnoj temperaturi	при предельной рабочей температуре ved temperatur for driftsgrense При граничній робочій температурі
Ⓣ		Backup-Heizleistung Capacité de chauffage d'appoint Reserveverwarmingscapaciteit Capacidad de calefacción auxiliar	Capacità di riscaldamento ad- dizionale Δυνατότητα εφεδρικής θέρμανσης Capacidade de aquecimento de reserva Reserveverarmekapacitet	Kapacitet för reservvärme Kapacita záložního vytápění Výkon záložného vykurovacieho telesa Kisegítő fűtési teljesítmény	Zapasowa pojemność grzewcza Rezervna zmogljivost ogrevanja Мощност на спомагателно електрическо подгряване Capacitate de încălzire de siguranță	Tagavara küttevõimsus Toileadh téimh chúltaca Rezerves šildītāja jauda Pagalbinio šildymo pajėgumas	Kapacitá tat-tishin ta' sostenn Varalämmitysteho Yedek ısıtma kapasitesi Kapacitet rezervnog grijanja	Резервная тепловая мощность Sikkerhedskapasitet for opvarm- ing Резервна теплава потужність

PRODUCT INFORMATION (*1)				
ROOM AIR CONDITIONER		INDOOR MODEL OUTDOOR MODEL		
		MSZ-AY35VGKP / MSZ-AY35VGK MUZ-AY35VG		
Function (indicate if present)				
cooling		Y		
heating		Y		
Item	symbol	value	unit	
Design load				
cooling	Pdesignc	3.5	kW	
heating/Average	Pdesignh	2.9	kW	
heating/Warmer	Pdesignh	1.6	kW	
heating/Colder	Pdesignh	x	kW	
Declared capacity for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				
Tj=35°C	Pdc	3.5	kW	
Tj=30°C	Pdc	2.6	kW	
Tj=25°C	Pdc	1.7	kW	
Tj=20°C	Pdc	1.0	kW	
Declared capacity for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=-7°C	Pdh	2.6	kW	
Tj=2°C	Pdh	1.6	kW	
Tj=7°C	Pdh	1.1	kW	
Tj=12°C	Pdh	0.7	kW	
Tj=bivalent temperature	Pdh	2.9	kW	
Tj=operating limit	Pdh	2.0	kW	
Declared capacity for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=2°C	Pdh	1.6	kW	
Tj=7°C	Pdh	1.1	kW	
Tj=12°C	Pdh	0.7	kW	
Tj=bivalent temperature	Pdh	1.6	kW	
Tj=operating limit	Pdh	2.0	kW	
Declared capacity for heating/Colder season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=-7°C	Pdh	x	kW	
Tj=2°C	Pdh	x	kW	
Tj=7°C	Pdh	x	kW	
Tj=12°C	Pdh	x	kW	
Tj=bivalent temperature	Pdh	x	kW	
Tj=operating limit	Pdh	x	kW	
Tj=-15°C	Pdh	x	kW	
Bivalent temperature				
heating/Average	Tbiv	-10	°C	
heating/Warmer	Tbiv	2	°C	
heating/Colder	Tbiv	x	°C	
Cycling interval capacity				
for cooling	Pcycc	x	kW	
for heating	Pcyhc	x	kW	
Degradation co-efficient cooling	Cdc	0.25	-	
Electric power input in power modes other than 'active mode'				
off mode	P _{OFF}	1	W	
standby mode	P _{SB}	1	W	
thermostat - off mode	P _{TO}	8	W	
crankcase heater mode	P _{CK}	0	W	
Capacity control (indicate one of three options)				
fixed		N		
staged		N		
variable		Y		
Contact details for obtaining more information				
MITSUBISHI ELECTRIC CORPORATION SHIZUOKA WORKS 3-18-1, Oshika, Suruga-ku, Shizuoka 422-8528, Japan E-mail: melshierp@MitsubishiElectric.co.jp				

If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.				
Average (mandatory)		Y		
Warmer (if designated)		Y		
Colder (if designated)		N		
Item	symbol	value	unit	
Seasonal efficiency				
cooling	SEER	8.7	-	
heating/Average	SCOP/A	4.7	-	
heating/Warmer	SCOP/W	5.9	-	
heating/Colder	SCOP/C	x	-	
Declared energy efficiency ratio, at indoor temperature 27(19)°C and outdoor temperature Tj				
Tj=35°C	EERd	3.6	-	
Tj=30°C	EERd	5.9	-	
Tj=25°C	EERd	10.6	-	
Tj=20°C	EERd	19.7	-	
Declared coefficient of performance/Average season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=-7°C	COPd	3.1	-	
Tj=2°C	COPd	4.6	-	
Tj=7°C	COPd	6.1	-	
Tj=12°C	COPd	7.0	-	
Tj=bivalent temperature	COPd	2.7	-	
Tj=operating limit	COPd	2.1	-	
Declared coefficient of performance/Warmer season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=2°C	COPd	4.6	-	
Tj=7°C	COPd	6.1	-	
Tj=12°C	COPd	7.0	-	
Tj=bivalent temperature	COPd	4.6	-	
Tj=operating limit	COPd	2.1	-	
Declared coefficient of performance/Colder season, at indoor temperature 20°C and outdoor temperature Tj				
Tj=-7°C	COPd	x	-	
Tj=2°C	COPd	x	-	
Tj=7°C	COPd	x	-	
Tj=12°C	COPd	x	-	
Tj=bivalent temperature	COPd	x	-	
Tj=operating limit	COPd	x	-	
Tj=-15°C	COPd	x	-	
Operating limit temperature				
heating/Average	Toi	-20	°C	
heating/Warmer	Toi	-20	°C	
heating/Colder	Toi	x	°C	
Cycling interval efficiency				
for cooling	EERcyc	x	-	
for heating	COPcyc	x	-	
Degradation co-efficient heating	Cdh	0.25	-	
Annual electricity consumption				
cooling	Q _{CE}	141	kWh/a	
heating/Average	Q _{HE}	863	kWh/a	
heating/Warmer	Q _{HE}	376	kWh/a	
heating/Colder	Q _{HE}	x	kWh/a	
Other items				
Sound power level (indoor/outdoor)	L _{WA}	57/61	dB(A)	
Global warming potential	GWP (*2)	675	kgCO ₂ eq.	
Rated air flow (indoor/outdoor)	-	666/1932	m ³ /h	

(*1) This information is based on the "product information requirement" in COMMISSION REGULATION (EU) No. 206/2012.

(*2) This GWP value is based on Regulation (EU) No. 517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2011, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.

TECHNICAL DOCUMENTATION ⁽¹⁾			
ROOM AIR CONDITIONER	INDOOR MODEL OUTDOOR MODEL	MSZ-AY35VGKP / MSZ-AY35VGK MUZ-AY35VG	299H*798W*245D (mm) 550H*800W*285D (mm)
Function			
cooling		Y	
heating		Y	
The heating season			
Average (mandatory)		Y	
Warmer (if designated)		Y	
Colder (if designated)		N	
Capacity control			
fixed		N	
staged		N	
variable		Y	
Item	symbol	value	unit
Seasonal efficiency ⁽²⁾			
cooling	SEER	8.7	-
heating/Average	SCOP/A	4.7	-
heating/Warmer	SCOP/W	5.9	-
heating/Colder	SCOP/C	x	-
Energy efficiency class			
cooling	SEER	A+++	-
heating/Average	SCOP/A	A++	-
heating/Warmer	SCOP/W	A+++	-
heating/Colder	SCOP/C	x	-
Other items			
Sound power level (indoor/outdoor)	L _{WA}	57/61	dB (A)
Refrigerant	-	R32	-
Global warming potential	GWP ⁽³⁾	675	kgCO ₂ eq.
Identification and signature of the person empowered to bind the supplier	 Kenichi Saito Department Manager, Quality Assurance Department Mitsubishi Electric Air Conditioning Systems Manufacturing Turkey Joint Stock Company		

(1) This information is based on COMMISSION DELEGATED REGULATION (EU) No. 626/2011.

(2) SEER/SCOP values are measured based on EN 14825:2016: Testing and rating at part load conditions and calculation of seasonal performance.

(3) This GWP value is based on Regulation (EU) No. 517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No. 626/2011, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.